

**COMMONWEALTH OF PENNSYLVANIA**  
**DEPARTMENT OF HUMAN SERVICES**  
**BUREAU OF HUMAN SERVICES LICENSING**  
**Adult Training Facilities** (55 Pa.Code Chapter 2380)

**Q/A - Regulatory Clarifications – February 2015**

*The clarifications and interpretations below will remain on the Department's web site until the information is included in the next updated Regulatory Compliance Guide (RCG).*

**Regulations:    § 2380.51 – Special Accommodations, § 2380.81 – Exits, § 2380.82 – Unobstructed Egress**

*§ 2380.51 - A facility serving one or more individuals with a physical disability, blindness, a visual impairment, deafness or a hearing impairment shall have accommodations to ensure the safety and reasonable accessibility for entrance to, movement within and exit from the facility based upon each individual's needs.*

*§ 2380.81 - Each building in which the facility operates shall have a minimum of two exits leading directly to the outside.*

*§ 2380.82 - Stairways, halls, doorways, aisles, passageways and exits from rooms and from the building shall be unobstructed.*

**Question:** If an adult training facility serves individuals who utilize wheelchairs, then do both of the two required exits leading directly to the outside have to be ramped?

**ANSWER:** Each building shall have a minimum of two accessible exits leading directly to the outside that meet the needs of the individuals served in the facility. If there are individuals served who use wheelchairs, then at least two exits to the outside should be equipped with ramps.

The application of these regulations will be effective one year – **April 1, 2016** - from the date of this clarification.